Link to the NYS Codes: <a href="http://publicecodes.cvberregs.com/st/nv/st/index.htm">http://publicecodes.cvberregs.com/st/nv/st/index.htm</a>

## SECTION 303 SWIMMING POOLS, SPAS AND HOT TUBS

**303.1 Swimming pools.** Swimming pools shall be maintained in a clean and sanitary condition, and in good repair.

**303.2 Enclosures.** The provisions of this section shall control the design of barriers for residential swimming pools, spas and hot tubs. For public swimming pools, spas and hot tubs refer to Chapter 31 of the *Building Code of New York State*. Design controls are intended to provide protection against potential drownings and near-drownings by restricting access to swimming pools, spas and hot tubs. **[B]** 

**Exception:** Spas or hot tubs with a safety cover that complies with ASTM F 1346 shall be exempt from the provisions of this section.

- **303.3 Outdoor swimming pool.** An outdoor swimming pool, including an in-ground, aboveground or on-ground pool, hot tub or spa shall be provided with a barrier which shall comply with the following:
  - 1. The top of the barrier shall be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches (51 mm) measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an aboveground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be 4 inches (102 mm).
  - 2. Openings in the barrier shall not allow passage of a 4- inch-diameter (102 mm) sphere.
  - 3. Solid barriers which do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.
  - 4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed 1.75 inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1.75 inches (44 mm) in width.
  - 5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing between vertical members shall not exceed 4 inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1.75 inches (44 mm) in width
  - 6. Maximum mesh size for chain link fences shall be a 2.25-inch (32 mm) square unless the fence is provided with slats fastened at the top or the bottom which reduce the openings to not more than 1.75 inches (44 mm).
  - 7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than 1.75 inches (44 mm).

- 8. Access gates shall comply with the requirements of Section 303.3, Items 1 through 7, and shall be securely locked with a key, combination or other child-proof lock sufficient to prevent access to the swimming pool through such gate when the swimming pool is not in use or supervised. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Gates other than pedestrian access gates shall have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from the bottom of the gate, the release mechanism and openings shall comply with the following:
- 8.1. The release mechanism shall be located on the pool side of the gate at least 3 inches (76 mm) below the top of the gate, and
- 8.2. The gate and barrier shall have no opening greater than 0.5 inch (12.7 mm) within 18 inches (457 mm) of the release mechanism.
- 9. Where a wall of a dwelling serves as part of the barrier one of the following conditions shall be met:
- 9.1. The pool shall be equipped with a powered safety cover in compliance with ASTM F 1346; or
- 9.2. All doors with direct access to the pool through that wall shall be equipped with an alarm which produces an audible warning when the door and/or its screen, if present, are opened. The alarm shall be listed in accordance with UL 2017. The audible alarm shall activate within 7 seconds and sound continuously for a minimum of 30 seconds immediately after the door and/or its screen, if present, are opened and be capable of being heard throughout the house during normal household activities. The alarm shall automatically reset under all conditions. The alarm system shall be equipped with a manual means, such as touch pad or switch, to temporarily deactivate the alarm for a single opening. Deactivation shall last for not more than 15 seconds. The deactivation switch(es) shall be located at least 54 inches (1372 mm) above the threshold of the door; or
- 9.3. Other means of protection, such as self-closing doors with self-latching devices shall be acceptable so long as the degree of protection afforded is not less than the protection afforded by Item 9.1 or 9.2 described above.
- 10. Where an aboveground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps, then:
- 10.1. The ladder or steps shall be capable of being secured, locked or removed to prevent access, or
- 10.2. The ladder or steps shall be surrounded by a barrier which meets the requirements of Section 303.3, Items 1 through 9. When the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a 4-inch-diameter (102 mm) sphere.
- **303.4 Indoor swimming pool.** All walls surrounding an indoor swimming pool shall comply with Section 303.3, Item 9.
- **303.5 Prohibited locations.** Barriers shall be located so as to prohibit permanent structures, equipment or similar objects from being used to climb the barriers.
- **303.6 Swimming pool and spa alarms.** Spas or hot tubs with a safety cover which complies with ASTM F 1346, shall be exempt from the provisions of this section.
  - **303.6.1** Applicability. A swimming pool or spa installed, constructed or substantially modified after December 14, 2006, shall be equipped with an approved pool alarm.

## **Exceptions:**

- 1. A hot tub or spa equipped with a safety cover which complies with ASTM F 1346.
- 2. A swimming pool (other than a hot tub or spa) equipped with an automatic power safety cover which complies with ASTM F 1346.

Pool alarms shall comply with ASTM F 2208 and shall be installed, used and maintained in accordance with the manufacturer's instructions and this section.

- **303.6.2 Multiple alarms.** A pool alarm must be capable of detecting entry into the water at any point on the surface of the swimming pool. If necessary to provide detection capability at every point on the surface of the swimming pool, more than one pool alarm shall be provided.
- **303.6.3 Alarm activation.** Pool alarms shall activate upon detecting entry into the water and shall sound poolside and inside the dwelling.
- **303.6.4 Prohibited alarms.** The use of personal immersion alarms shall not be construed as compliance with this section.
- **303.7 Temporary barriers.** An outdoor swimming pool, including an in-ground, above-ground or on-ground pool, hot tub or spa shall be surrounded by a temporary barrier during installation or construction and shall remain in place until a permanent barrier in compliance with <u>Section 303.3</u> is provided.

## **Exceptions:**

- 1. Above-ground or on-ground pools where the pool structure is the barrier in compliance with <u>Section 303.3.</u>
- 2. Spas or hot tubs with a safety cover which complies with ASTM F 1346, provided that such safety cover is in place during the period of installation or construction of such hot tub or spa. The temporary removal of a safety cover as required to facilitate the installation or construction of a hot tub or spa during periods when at least one person engaged in the installation or construction is present is permitted.
- **303.7.1 Height.** The top of the temporary barrier shall be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool.
- **303.7.2 Replacement by a permanent barrier.** A temporary barrier shall be replaced by a complying permanent barrier within either of the following periods:
- 1. 90 days of the date of issuance of the building permit for the installation or construction of the swimming pool; or
- 2. 90 days of the date of commencement of the installation or construction of the swimming pool.
- 303.7.2.1 Replacement extension. Subject to the approval of the code enforcement official, the time period for completion of the permanent barrier may be extended for good cause, including, but not limited to, adverse weather conditions delaying construction.
- **303.8** Entrapment protection for swimming pools and spas. Swimming pools and spas shall maintain body entrapment protections for suction outlets in accordance with the *Building Code of New York State* or the *Residential Code of New York State*, as applicable.